KOBOLD Model NDT Static Pressure Level Switch User Instructions





USA

1801 Parkway View Drive Pittsburgh, PA 15205 PH 412-788-2830 Canada

9A Aviation Point Claire, QC H9R 4Z2 PH 514-428-8090

www.koboldusa.com

Order from: C A Briggs Company


622 Mary Street; Suite 101; Warminster, PA 18974 Phone: 267-673-8117 - Fax: 267-673-8118 Sales@cabriggs.com - www.cabriggs.com

Description

The KOBOLD model NDT level switch uses the static pressure principle to monitor the level in open or vented tanks. The unit operates as follows:

- 1. The rising liquid level will provide a confined air volume in a user supplied pipe when the liquid reaches the bottom edge of the pipe.
- 2. As the liquid level continues to rise, the air trapped inside the pipe is compressed.
- 3. The switching will occur when the air inside the pipe is compressed to a pressure of 4 inches of water column.
- 4. The result is a level switch whose switchpoint is fixed at 4 inches above the bottom edge of the user supplied pipe. This allows the user to set his switchpoint by simply attaching the appropriate length pipe to the NDT level switch.

Electrical Connections



1 = Common

2 = Normally Closed

3= Normally Open

Technical Specifications

Wetted Parts

Exposed to Liquid:

Exposed to air pocket:

User supplied pipe
NBR, Polyamide

Housing: Polyamide **Media:** Any free flowing liquid

Fittings:

NDT-2020 1/2" BSP

NDT-2080 1-1/4" Hose fitting

(accommodates 1" SCH 40 or SCH 80) **Switchpoint**: 4" above the end of user supplied pipe

Switch Error: ±10%
Temperature Range: 15 to 185°F

Electrical Characteristics:

Switch Type: SPDT

Maximum Rating: 250 VAC, 8 Amp resistive, 1.5 Amp

inductive

Protection: NEMA 4

Precautions

The following precautions must be adhered to at all times when using the model NDT flow switch:

- Inspect the instrument for damage upon arrival. Cracked, fractured or otherwise damaged instruments must not be put into use since the device is weakened to an unknown extent. If necessary, contact KOBOLD Instruments, Inc. for further guidance on making claims for damaged instruments.
- UNDER NO CIRCUMSTANCES must the maximum tolerances of temperature, pressure or electrical loading be exceeded.
- Double check all electrical connections prior to placing the unit into service. Miswired electrical connections can cause immediate and permanent damage to the instrument.

<u>Installation Instructions</u>

- The model NDT level switch must be mounted above the top of the tank to ensure that
 the fluid inside the tank will not contact the switch internals. If the fluid is permitted to
 flood the switch internals, the setpoint may be permanently altered or the switch may
 otherwise be damaged.
- 2. The pipe which is to be connected to the switch must be cut such that it extends into the tank 4 inches farther than the desired setpoint. For example, if the desired switchpoint is 12 inches below the top of the tank, the pipe should be cut such that it extends 16 inches into the tank.
- 3. If the unit with a threaded pipe connection is being used, a thread sealant such as PTFE tape should be applied to the threads to ensure an air-tight fit.
- 4. After all electrical connections are made, ensure that both the housing lid and the cable gland are tightly secured. This will ensure the watertight integrity of the unit.
- 5. Both the level switch and the pipe must be rigidly supported to prevent damage to the pipe fitting and subsequent switch malfunction.

<u>Maintenance</u>

Since the NDT level switch is designed to function without contacting the media, virtually no maintenance is required. It is recommended that an occasional inspection of the electrical connections is made to ensure that all connections are tight, and that no corrosion exists. Additionally, if the process media tends to coat tanks and piping, it is recommended that the pressure pipe be removed and cleaned on a periodic basis.

Questions

Call one of our friendly engineers at 800-998-1020.